

**FITNESS CERTIFICATE**

TO BE FILLED BY THE INSPECTING OFFICER  
(Assistant Engineer/ Assistant Executive Engineer )

Name of School

: Markazul Ulloom English Higher Secondary Ekkaparamba,  
Kuzhimanna

1 Name of Officer

: Sudeshna paloli

2 Location

: Ekkaparamba

3 Period which the certificate is issued

: 2021-22

4 Types of Building

: RCC Building

B block Buiding

Ground floor 6 class room (6.00x6.00x3.65 m)  
2 m wide Verandah  
First floor 6 class room (6.00x6.00x3.65)m  
Staff room (3.70x2.70x3.65)m 1 No  
2 m wide Verandah  
Second floor 6 class room (6.00x6.00x3.65)m  
Staff room 1 room (3.70x2.70x3.65)m  
2 m wide Verandah

A block Buiding

Ground floor 9 class room (6.00x6.00x3.55 m)  
Principal room 1 (3.60x2.80x3.55)m  
Office room 1 (5.80x2.80x3.55)m  
1.9 m wide Verandah  
First floor 4 class room (6.00x6.00x3.55 m)  
Lab 3 Nos 12x6x3.55m)  
Staff room 1No (4x3.80x3.55)m  
1.90 m wide Verandah  
Second floor 6 class room (6.00x6.00x3.55 m)  
Library 1 No 12x6x3.55m)  
Lab 1 No 12x6x3.55m)  
Staff room 1 room (4x3.80x3.55)m  
1.90 m wide Verandah

C block Buiding

Ground floor 4class room (6.00x6.10x3.60 m)  
2 m wide Verandah  
First floor 4 class room (6.00x6.10x3.60)m  
2 m wide Verandah  
Second floor 4 class room (6.00x6.10x3.60)m  
2 m wide Verandah

5 Nature of defects if any

a) Foundation and basement

b) Superstructure

c) Doors and windows

d) Wood work wrought and put up

e) Roof

f) Flooring

g) Miscellaneous (cracks if any)

Nil

6 Any major defects noticed which will  
render the building unsafe in any manner

: No

7 Whether maintenance work have been  
done properly

: Yes

8 Whether the structure is sound or not  
for conducting classes.

: Yes. Sound for conducting classes  
under normal wind and weather conditions.


Note : 1) The stability of the structure should be examined also with reference to location,  
altitude intensity of wind exposure to flood etc.

2) Any additional observation deemed necessary for the certificate, may be furnished  
separately with the certificate

Certified that the school was inspected by me on 29-10-2021 and found to be fit  
to conduct classes for the period for the reasons stated above.

Place : Kuzhimanna

Date : 29-10-2021



Signature  
Designation  
**ASSISTANT ENGINEER**  
**LSGD SECTION**  
**KUZHIMANNA**

*Self attested*  
*[Signature]*  
23/06/23  
Principal  
Markazul Ulloom English School  
Kondotty-673 638